

SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Jim Doyle, Governor Richard J. Leinenkugel, Secretary

August 25, 2009

ECOWATER SYSTEMS LLC MARGARET BICKING 1890 WOODLANE DR WOODBURY MN 55125

MORTON MARGARET L. BICKING PO BOX 25290 WOODBURY MN 55125

Re: Description: WATER TREATMENT DEVICE- ACTIVATED CARBON

Manufacturer: MORTON

Product Name: MORTON SYSTEM SAVER (POE)

Model Number(s): MCWF (POE) Product File No: 20090218

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160. Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2014.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those contaminants and/or substances as specified in this approval letter when the product is installed and maintained in strict accordance with the manufacturers published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 266-3415.
- If this approved device is modified or additional assertions of function or performance are made, then this approval shall be considered null and void, unless the change is submitted to the department for review and the approval is reaffirmed.
- Operation of this/these device(s) and flow rates above the rated service flow rates indicated within this approval letter are not supported or acknowledged by this approval. The rated service flow rate(s) is/are the flow rate(s) at which this/these device(s) were tested.

Because the level of treatment obtained is a function of how long the water is in contact with the treatment media within this/these device(s), arbitrary increases in the flow rate(s), above the rated service flow rate(s) may compromise the quality of the treated water.

Based on testing data submitted to and reviewed by the department, this approval recognizes that this plumbing product will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

SBD-10564-E (N.10/97) File Ref: 09021801.DOC

Morton August 25, 2009 Page 2 of 2

Product File No.: 20090218

AESTHETIC CONTAMINANT REDUCTION CAPABILITIES PRODUCT FILE NUMBER 20090218 TABLE 1 OF 1

Flow Rate: 22.7 liters per minute (lpm) [6.0 gallon per minute (gpm)]

Capacity: 2,157,685 liters (I) [570,000 gallons (gals.)]. For particulate reduction the capacity is dependent on the type and quantity of particulate matter present in the untreated water;

the need for maintenance may be indicated be a significant decrease in flow rate.

Tested Contaminant	Influent Challenge (mg/l)*, 1
Chlorine (free)	2.0 ± 10%
Particulates (≥ 30 to ≤ 40.0 μm)	3,070 #/120ml
Particulates (≥ 40 to ≤ 50.0 µm)	1,706 #/120ml

Other Conditions: the free chlorine reduction performance capabilities displayed for Table 1 of 1 were verified by testing conducted in accordance with NSF *International* Standard 42. To qualify for free chlorine reduction, the device must reduce the influent challenge concentrations by \geq 50%; meeting the free chlorine reduction requirements also qualifies the device for the reduction of aesthetic, organic, taste and odor reduction (e.g. geosmin, methylisoborneol); this does not include hydrogen sulfide. The particulate reduction performance capabilities displayed for Table 1 of 1 were verified by testing conducted in accordance with ASTM F795-88. The device retained 96.4% of particles \geq 30 to \leq 40.0 μ m and 99.4% of particles \geq 40 to \leq 50.0 μ m.

1 = milligrams per liter (mg/l) are equivalent to parts per million (ppm)

≥ = greater than or equal to

± = plus or minus

#/ml = particles per milliliter

 \leq = less than or equal to μm = micrometers

* = unless otherwise specified

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 **Phone**(608) 267-9566 **Fax**glen.schlueter@wi.gov **Email**8:00AM – 4:30PM CDT **Work Hours**

GWS:gws